Melbourne Branch: 15 Beverage Dr, Tullamarine, 3043 Victoria, Australia P.O. Box 3272 Caroline Springs VIC 3023

Phone: 03 9310 3892

Fax: 03 9338 0924 Email: sales@davmarindustries.com.au



ACN 122 012 202

Sydney Branch: 11/30 Barry Road Chipping Norton 2170 New South Wales, Australia P.O. Box 3277 Lansvale NSW 2166 Phone: 02 9755 0716 Fax: 02 9755 0715 Email: sydney@davmarindustries.com.au

Specification Report: Scaffold-mesh

ABN 56 122 012 202

Weight: 80gsm +/- 5%

Construction: HDPE Knitted Yarn

UV Inhibitor – 3%

Testing Method: AS 2001.2.10-1986 (Tear Resistance)

Wing Rip

Test Result: Length: 85.1 N Width: 62.9 N

Testing Method: AS 2001.2.3.2-2001 (Breaking force of Textile Fabric)

Grab Test

Gauge Length: 75mm Speed: 300mm/min

Test Result: Length: 450 N Width: 331 N

Testing Method: AS 2001.2.4-1990 (Bursting Pressure of Textile Fabric)

Method B - Hydraulic Diaphragm Method

Test Result: 1180 Kpa

Testing Method: AS 2001.2.19-1988 (Bursting Force)

Steel Ball Diameter: 25.4mm

Test Result: Mean: 637 N

Test in Dry State